

ORDINANCE NO. 1106

AN ORDINANCE REPEALING AND REPLACING PARTS OF ARTICLE 3.100, SECTION 3.101 AND SECTION 3.102 OF THE CODE OF ORDINANCES OF CITY OF LEVELLAND CODE AND ALL OTHER ORDINANCES AND PARTS OF ANY ORDINANCES IN CONFLICT THEREWITH; AMENDING CERTAIN SECTIONS BY ADOPTING THE 2021 EDITION OF THE INTERNATIONAL FUEL GAS CODE AND PROVIDING PARTICULAR LOCAL MODIFICATION THERETO; PROVIDING A SEVERABILITY CLAUSE; AND PROVIDING AN EFFECTIVE DATE

WHEREAS, the City's Code of Ordinances Chapter 3, Building & Construction, Article 3.100 Standard Codes, Section 3.101 provides for the adoption of International Building Code (2015 edition), International Residential Code (2015 edition), International Plumbing Code (2015 edition), International Fuel Gas Code (2015 edition), International Mechanical Code (2015 edition), International Energy Conservation Code, (2009 edition), International Property Maintenance Code, (2015 edition), Life Safety Code (2015 edition), International Fire Code (2015 edition), National Electrical Code (2014 edition), and the International Existing Building Code (2015 edition), with certain local amendments provided for in Article 3.102; and

WHEREAS, the City Council now wishes to adopt the 2021 of the International Fuel Gas Code, as published by the International Code Council, with certain local modifications as specified herein; and

WHEREAS, the City Council finds the following amendment to be reasonable and beneficial and in the best interest of and best serves the public health, safety, and welfare of the residents of the City of Levelland, Texas and will provide regulatory consistency for effective and meaningful enforcement;

NOW THEREFORE, BE IT ORDAINED by the City Council of the City of Levelland, Texas that the Code of Ordinances is amended by repealing parts of Chapter 3, Building & Construction, Article 3.100, Standard Codes, Sections 3.101 and 3.102, and replacing these Sections to read, in part, as follows (note to codifier, the Section numbering may need to be revised):

SECTION I
General

§ 28.15.001. Adopted.

The 2021 edition of the International Fuel Gas Code, as published by the International Code Council, Inc., as hereinafter amended, including appendices A, B, C and D, is hereby adopted as the fuel gas code of the City of Levelland, Texas. A copy of said code is attached hereto and incorporated herein as though set out herein in detail. References to the fuel gas code in this chapter shall mean the 2021 edition of the International Fuel Gas Code. One copy of the 2021 International Fuel Gas Code shall be filed with the city secretary and a copy shall be maintained in the office of the city building official. All such copies, with the amendments thereto, shall be open to public

inspection during the usual hours of business of the offices where they are maintained.

§ 28.15.002. Coordination of administrative provisions.

The administrative provisions contained in chapter 3 of this Code of Ordinances are applicable to this article; however, for purposes of administering provisions related more specifically to the regulation of fuel gas systems installation, these supplemental administrative provisions have been provided. Except as amended or supplemented within sections 28.15.002 and 28.15.003, the entire text of chapter 1, of the 2021 International Fuel Gas Code is deemed to be incorporated herein as though set out herein in detail. Where a conflict arises between a provision contained within sections 28.15.002 and 28.15.003 and chapter 3 of this Code of Ordinances, it is the intent that the more specific govern, as determined by the building official.

§ 28.15.003. Intentionally omitted.

§ 28.15.004. Amendments.

(a) Sloped roofs. Section 306.5.1 is hereby amended to read as follows:

306.5.1 Sloped roofs. Where appliances, *equipment*, fans or other components that require service are installed on a roof having a slope of 6 units vertical in 12 units horizontal (50 percent slope) or greater and having an edge more than 30 inches (762 mm) above grade at such edge, a level platform shall be provided on each side of the *appliance* or *equipment* to which *access* is required for service, repair or maintenance. The platform shall be not less than 30 inches (762 mm) in any dimension and shall be provided with guards. The guards shall extend not less than 42 inches (1067 mm) above the platform, shall be constructed so as to prevent the passage of a 21-inch-diameter (533 mm) sphere and shall comply with the loading requirements for guards specified in the *International Building Code*. *Access* shall not require walking on roofs having a slope greater than 6 units vertical in 12 units horizontal (50 percent slope). Where *access* involves obstructions greater than 30 inches (762 mm) in height, such obstructions shall be provided with ladders installed in accordance with Section 306.5 or stairways installed in accordance with the requirements specified in the *International Building Code* in the path of travel to and from appliances, fans or *equipment* requiring service.

(b) Auxiliary drain pan. Section 307.5 is hereby amended to read as follows:

307.5 Auxiliary drain pan. Category IV condensing *appliances* shall be provided with an auxiliary drain pan where damage to any building component will occur as a result of stoppage in the condensate drainage system. Such pan will be installed in accordance with the applicable provisions of Section 307 of the *International Mechanical Code*.

(c) Protection methods against corrosion.

Section 404.11.2 is hereby amended to read as follows:

404.11.2 Protection methods. Underground *piping* shall comply with one or more of the following:

1. The *piping* shall be made of corrosion-resistant material that is suitable for the environment in which it will be installed.

2. Pipe shall have a factory-applied, electrically-insulating coating. Fittings and joints between sections of coated pipe shall be coated in accordance with the coating manufacturer's instructions.
3. The *piping* shall have a cathodic protection system installed and the system shall be monitored and maintained in accordance with an *approved* program.
4. *Approved* protective coatings or wrap may be field installed if piping that has a factory-applied, electrically-insulating coating is not readily available.

(d) Located at manifold. Section 409.5.3 is hereby amended to read as follows:

409.5.3 Located at manifold. Where the *appliance* shutoff valve is installed at a manifold, such shutoff valve shall be located within 50 feet (15,240 mm) of the *appliance* served and shall be readily accessible and permanently identified. The *piping* from the manifold to within 6 feet (1829 mm) of the *appliance* shall be designed, sized and installed in accordance with Sections 401 through 408. Shutoff valves located within attic spaces shall not be considered readily accessible.

(e) Pressure regulators. Section 410.1 is hereby amended to read as follows:

410.1 Pressure regulators. A line pressure regulator shall be installed where the *appliance* is designed to operate at a lower pressure than the supply pressure. Line gas pressure regulators shall be *listed* as complying with ANSI Z21.80/CSA 6.22. *Access* shall be provided to pressure regulators. Regulators shall be located near walkways or at an access point. Pressure regulators shall be protected from physical damage. Regulators installed on the exterior of the building shall be *approved* for outdoor installation.

(f) Log lighters. Section 603 is hereby deleted in its entirety.

(g) Exhaust material. Section 614.4 is hereby amended to read as follows:

614.4 Exhaust installation. Exhaust ducts for clothes dryers shall terminate on the outside of the building and shall be equipped with a backdraft damper. Screens shall not be installed at the duct termination. Ducts shall not be connected or installed with sheet metal screws or other fasteners that will obstruct the flow. Clothes dryer exhaust ducts shall not be connected to a vent connector, vent or chimney. Clothes dryer exhaust ducts shall not extend into or through ducts or plenums unless properly sleeved with materials conforming to Section 602.2.1 of the *International Mechanical Code* (in the case of plenums), or with materials meeting the requirements for class 0 or 1 duct materials (in the case of ducts). Backdraft dampers shall not be required for vertical terminations through the roof.

(h) Protection required. Section 614.8 is hereby amended to read as follows:

614.8 Protection required. Protective shield plates shall be placed where nails or screws from finish or other work are likely to penetrate the clothes dryer exhaust duct. Shield plates shall be placed on the finished face of all framing members where there is less than 1.25 inches (32 mm) between the duct and the finished face of the framing member. Such shield plates shall have a thickness of not less than 0.0575 inch (1.463 mm) (No. 16 gage). Such plates shall cover the area of the duct where the member is notched or bored.

SECTION II Severability

The provisions of this ordinance are declared to be severable. If any section, sentence, clause or phrase of the ordinance shall for any reason be held to be invalid or unconstitutional by a court of competent jurisdiction, such decision shall not affect the validity of the remaining sections, sentences, clauses, and phrases of this ordinance, but they shall remain in full force and effect; it being the legislative intent that this ordinance shall remain in effect notwithstanding the validity of any part.

SECTION III Effective Date

This Ordinance shall take effect immediately upon its adoption by the City Council and publication as may be required by governing law.

SECTION IV Open Meetings

It is hereby officially found and determined that the meeting at which this Ordinance is passed was open to the public as required and that public notice of the time, place, and purpose of said meeting was given as required by the *Open Meetings Act, Chapter 551, Gov't. Code*.

SECTION V Provisions Cumulative

All other terms and provisions of the Levelland Code of Ordinances not in conflict herewith and not hereby amended shall remain in full force and effect. The passage of this Ordinance shall repeal any wording of any existing ordinance that conflicts with the wording of this Ordinance.

INTRODUCED, PASSED, and APPROVED on its first reading this 1st day of December, 2025.

PASSED, APPROVED, and ADOPTED on its second and final reading this 15th day of December, 2025.

CITY OF LEVELLAND, TEXAS

By: _____
Breann Buxkemper, Mayor

ATTEST:

Andréa Corley, TRMC
City Secretary

ORDINANCE NO. 1107

AN ORDINANCE REPEALING AND REPLACING PARTS OF ARTICLE 3.100, SECTION 3.101 AND SECTION 3.102 OF THE CODE OF ORDINANCES OF CITY OF LEVELLAND CODE AND ALL OTHER ORDINANCES AND PARTS OF ANY ORDINANCES IN CONFLICT THEREWITH; AMENDING CERTAIN SECTIONS BY ADOPTING THE 2021 EDITION OF THE INTERNATIONAL MECHANICAL CODE AND PROVIDING PARTICULAR LOCAL MODIFICATION THERETO; PROVIDING A SEVERABILITY CLAUSE; AND PROVIDING AN EFFECTIVE DATE

WHEREAS, the City's Code of Ordinances Chapter 3, Building & Construction, Article 3.100 Standard Codes, Section 3.101 provides for the adoption of International Building Code (2015 edition), International Residential Code (2015 edition), International Plumbing Code (2015 edition), International Fuel Gas Code (2015 edition), International Mechanical Code (2015 edition), International Energy Conservation Code, (2009 edition), International Property Maintenance Code, (2015 edition), Life Safety Code (2015 edition), International Fire Code (2015 edition), National Electrical Code (2014 edition), and the International Existing Building Code (2015 edition), with certain local amendments provided for in Article 3.102; and

WHEREAS, the City Council now wishes to adopt the 2021 edition of the International Mechanical Code, as published by the International Code Council, with certain local modifications as specified herein; and

WHEREAS, the City Council finds the following amendment to be reasonable and beneficial and in the best interest of and best serves the public health, safety, and welfare of the residents of the City of Levelland, Texas and will provide regulatory consistency for effective and meaningful enforcement;

NOW THEREFORE, BE IT ORDAINED by the City Council of the City of Levelland, Texas that the Code of Ordinances is amended by repealing parts of Chapter 3, Building & Construction, Article 3.100, Standard Codes, Sections 3.101 and 3.102, and replacing these Sections to read, in part, as follows (note to codifier, the Section numbering may need to be revised):

SECTION I
General

§ 28.11.001. Adopted.

The 2021 edition of the International Mechanical Code, as published by the International Code Council, Inc., as hereinafter amended, including appendix A, is hereby adopted as the mechanical code of the City of Levelland, Texas. A copy of said code is attached hereto and incorporated herein as though set out herein in detail. References to the mechanical code in this chapter or to "this code" within this article shall mean and refer to the 2021 edition of the International Mechanical

Code as amended herein. One copy of the 2021 International Mechanical Code shall be filed with the city secretary and a copy shall be maintained in the office of the city building official. All such copies, with the amendments thereto, shall be open to public inspection during the usual hours of business of the offices where they are maintained.

§ 28.11.002. Coordination of administrative provisions.

The administrative provisions contained in chapter 3 of this Code of Ordinances are applicable to this article; however, for purposes of administering provisions related more specifically to the regulation of mechanical systems installation, these supplemental administrative provisions have been provided. Except as amended or supplemented within sections 28.11.002 and 28.11.003, the entire text of chapter 1, of the 2021 International Mechanical Code is deemed to be incorporated herein as though set out herein in detail. Where a conflict arises between a provision contained within sections 28.11.002 and 28.11.003 and chapter 3 of this Code of Ordinances, it is the intent that the more specific govern, as determined by the building official.

§ 28.11.003. Intentionally omitted.

§ 28.11.004. Amendments.

(a) Guards.

Section 304.11 is hereby amended to read as follows:

304.11 Guards. Guards shall be provided where various components that require service and roof hatch openings are located within 10 feet (3048 mm) of a roof edge or open side of a walking surface and such edge or open side is located more than 30 inches (762 mm) above the floor, roof, or grade below. The guard shall extend not less than 30 inches (762 mm) beyond each end of components that require service. The top of the guard shall be located not less than 42 inches (1067 mm) above the elevated surface adjacent to the guard. The guard shall be constructed so as to prevent the passage of a 21-inch-diameter (533 mm) sphere and shall comply with the loading requirements for guards specified in the *International Building Code*.

Exceptions:

1. Guards are not required where permanent fall arrest/restraint anchorage connector devices that comply with ANSI/ASSE Z 359.1 are affixed for use during the entire lifetime of the roof covering. The devices shall be re-evaluated for possible replacement when the entire roof covering is replaced. The devices shall be placed not more than 10 feet (3048 mm) on center along hip and ridge lines and placed not less than 10 feet (3048 mm) from roof edges and the open sides of walking surfaces.
2. Guards are not required to be installed upon replacement of legally-installed pre-existing rooftop appliances and equipment within existing rough openings that would otherwise be subject to Section 304.11, provided that a fall hazard warning sign is affixed to the service access side of the equipment.

(b) Sloped roofs. Section 306.5.1 is hereby amended to read as follows:

306.5.1 Sloped roofs. Where *appliances, equipment, fans* or other components that require

service are installed on a roof having a slope of six units vertical in 12 units horizontal (50 percent slope) or greater and having an edge more than 30 inches (762 mm) above grade at such edge, a level platform shall be provided on each side of the *appliance* or *equipment* to which access is required for service, repair or maintenance. The platform shall not be less than 30 inches (762 mm) in any dimension and shall be provided with guards. The guards shall extend not less than 42 inches above the platform, shall be constructed so as to prevent the passage of a 21-inch diameter sphere and shall comply with the loading requirements for guards specified in the *International Building Code*. Access shall not require walking on roofs having a slope greater than 6 units vertical in 12 units horizontal (50 percent slope). Where access involves obstructions greater than 30 inches in height, such obstructions shall be provided with ladders installed in accordance with Section 306.5 or stairways installed in accordance with the requirements specified in the *International Building Code* in the path of travel to and from *appliances*, fans or *equipment* requiring service.

(c) Drain piping materials and sizing. Section 307.2.2 is hereby amended to read as follows:

307.2.2 Drain piping materials and sizing. Components of the condensate disposal system shall be ABS, cast-iron, copper and copper-alloy, CPVC, cross-linked polyethylene, galvanized steel, PE-RT, polyethylene, polypropylene, PVC, or PVDF piping or tubing. Components shall be selected for the pressure and temperature rating of the installation. Joints and connections shall be made in accordance with the applicable provisions of Chapter 7 of the *International Plumbing Code* relative to the material type. Condensate waste and drain line shall not be less than 3/4 inch (19.1mm) pipe size. Where the drain pipes from more than one unit are manifolded together for condensate drainage, the pipe or tubing shall be sized in accordance with Table 307.2.2. Piping that is reduced in size from the drain pan connection to a size that is in accordance with Table 307.2.2 must use eccentric fittings for the size reduction in horizontal piping. If the size reduction occurs in vertical piping concentric fittings may be used.

(d) Auxiliary and secondary drain systems.

Section 307.2.3 is hereby amended to read as follows:

307.2.3 Auxiliary and secondary drain systems. In addition to the requirements of Section 307.2.1, where damage to any building components could occur as a result of overflow from the *equipment* primary condensate removal system, one of the following auxiliary protection methods shall be provided for each cooling coil or fuel-fired *appliance* that produces condensate:

1. An auxiliary drain pan with a separate drain shall be provided under the coils on which condensation will occur. The auxiliary pan drain shall discharge to a conspicuous point of disposal to alert occupants in the event of a stoppage of the primary drain. The pan shall have a minimum depth of 1-1/2 inches (38 mm), shall be not less than 3 inches (76 mm) larger than the unit, or the coil dimensions in width and length and shall be constructed of corrosion-resistant material. Galvanized sheet steel pans shall have a minimum thickness of not less than 0.0236 inch (0.6010 mm) (No. 24 gage). Nonmetallic pans shall have a minimum thickness of not less than 0.0625 inch (1.6 mm).
2. A separate overflow drain line shall be connected to the drain pan provided with the *equipment*. Such overflow drain shall discharge to a conspicuous point of disposal to

alert occupants in the event of a stoppage of the primary drain. The overflow drain line shall connect to the drain pan at a higher level than the primary drain connection.

3. An auxiliary drain pan without a separate drain line shall be provided under the coils on which condensate will occur. Such pan shall be equipped with a water-level detection device conforming to UL 508 that will shut off the *equipment* served prior to overflow of the pan. The auxiliary drain pan shall be constructed in accordance with Item 1 of this section.

(e) Ductless mini-split system traps. Section 307.2.4.1 is hereby deleted in its entirety.

(f) Ventilation required. Section 401.2 is hereby amended to read as follows:

401.2 Ventilation required. Every occupied space shall be ventilated by natural means in accordance with Section 402 or by mechanical means in accordance with Section 403.

(g) Local exhaust. Section 403.3.2.3 is hereby amended to read as follows:

403.3.2.3 Local exhaust. Local exhaust systems shall be provided in kitchens, bathrooms and toilet rooms and shall have the capacity to exhaust the minimum airflow rate determined in accordance with Table 403.3.2.3.

Table 403.3.2.3

Minimum Required Local Exhaust Rates for Group R-2, R-3, and R-4 Occupancies

Area to be Exhausted	Exhaust Rate Capacity
Kitchens	100 cfm intermittent or 25 cfm continuous
Bathrooms & toilet rooms	50 cfm intermittent or 20 cfm continuous

Exception: The normal operation of bathroom and toilet room exhaust fans, as well as kitchen range hood fans shall be considered adequate to satisfy the intermittent exhaust rate requirements without the addition of additional exhaust fans.

(h) Exhaust installation. Section 504.4 is hereby amended to read as follows:

504.4 Exhaust installation. Dryer exhaust ducts for clothes dryers shall terminate on the outside of the building and shall be equipped with a back draft damper. Screens shall not be installed at the duct termination. Ducts shall not be connected or installed with sheet metal screws or other fasteners that will obstruct the exhaust flow. Clothes dryer exhaust ducts shall not be connected to a vent connector, vent or *chimney*. Clothes dryer exhaust ducts shall not extend into or through ducts or *plenums*.

Exception: Back draft dampers shall not be required for vertical duct penetrations through roofs.

(i) Length identification. Section 504.9.5 is hereby amended to read as follows:

504.9.5. Length identification. Where the exhaust duct is concealed within the building construction and exceeds a total developed length of 35 feet, the equivalent length of the exhaust duct shall be identified on a permanent label or tag. The label or tag shall be located

within 6 feet of the exhaust duct connection.

(j) Common exhaust systems for clothes dryers in multi-story structures. Section 504.11 is hereby amended to read as follows:

504.11. Common exhaust systems for clothes dryers located in multi-story structures. Where a common multistory duct system is designed and installed to convey exhaust from multiple clothes dryers, the construction of the system shall be in accordance with all of the following:

1. The shaft in which the duct is installed shall be constructed and fire-resistance rated as required by the *International Building Code*.
2. Dampers shall be prohibited in the exhaust duct. Penetrations of the shaft and ductwork shall be protected in accordance with Section 607.5.5, Exception 2.
3. Rigid metal ductwork shall be installed within the shaft to convey the exhaust. The ductwork shall be constructed of sheet steel having a minimum thickness of 0.0187 inch (No. 26 gage) and in accordance with SMACNA Duct Construction Standards.
4. The ductwork within the shaft shall be designed and installed without offsets.
5. The exhaust fan motor design shall be in accordance with Section 503.2.
6. The exhaust fan motor shall be located outside of the airstream.
7. The exhaust fan shall run continuously.
8. Exhaust fan operation shall be monitored in an *approved* location and shall initiate an audible or visual signal when the fan is not in operation.
9. *Makeup* air shall be provided for the exhaust system.
10. A cleanout opening shall be located at the base of the shaft to proved *access* to the duct to allow for cleaning and inspection. The finished opening shall be not less than 12 inches by 12 inches.
11. Screens shall not be installed at the termination.
12. The common multi story duct system shall serve only clothes dryers and shall be independent of other exhaust systems

(k) Return air openings.

Section 601.5 is hereby amended to read as follows:

601.5 Return air openings. Return air openings for heating, ventilation and air-conditioning systems shall comply with all of the following:

1. Openings shall not be located less than 10 feet (3048 mm) measured in any direction from an open combustion chamber or draft hood of another *appliance* located in the same room or space.
2. Return air shall not be taken from a hazardous or insanitary location or a refrigeration room as defined in this code.
3. The amount of return air taken from any room or space shall be not greater than the flow

rate of supply air delivered to such room or space, except as necessary to make up air from a space on a common system where drawing return air is prohibited.

4. Return and transfer openings shall be sized in accordance with the *appliance* or *equipment* manufacturer's installation instructions, ACCA Manual D or the design of the registered design professional.
5. Return air taken from one *dwelling unit* shall not be discharged into another *dwelling unit*.
6. Taking return air from a crawl space shall not be accomplished through a direct connection to the return side of a forced air furnace. Transfer openings in the crawl space enclosure shall not be prohibited.
7. Return air shall not be taken from a closet, bathroom, toilet room, kitchen, garage, boiler room, furnace room or unconditioned attic.
8. Return air shall not be taken from indoor swimming pool enclosures and associated deck areas.

Exceptions:

1. Where the air from such spaces is dehumidified in accordance with Section 403.2.1, Item 2.
2. Dedicated HVAC systems serving only such places.

Exceptions:

1. Taking return air from a kitchen is not prohibited where such return air openings serve the kitchen and are located not less than 10 feet (3048mm) from the cooking *appliances*.
2. Taking return air from a kitchen is not prohibited in a *dwelling unit* where the kitchen and living spaces are in a single room and the cooking *appliance* is electric and located not less than 5 feet (1524mm) in any direction from the return air intake opening.
3. Dedicated forced air systems serving only the garage shall not be prohibited from obtaining return air from the garage.

(l) Access port protection. Section 1102.3 is hereby deleted in its entirety.

SECTION II

Severability

The provisions of this ordinance are declared to be severable. If any section, sentence, clause or phrase of the ordinance shall for any reason be held to be invalid or unconstitutional by a court of competent jurisdiction, such decision shall not affect the validity of the remaining sections, sentences, clauses, and phrases of this ordinance, but they shall remain in full force and effect; it being the legislative intent that this ordinance shall remain in effect notwithstanding the validity of any part.

SECTION III
Effective Date

This Ordinance shall take effect immediately upon its adoption by the City Council and publication as may be required by governing law.

SECTION IV
Open Meetings

It is hereby officially found and determined that the meeting at which this Ordinance is passed was open to the public as required and that public notice of the time, place, and purpose of said meeting was given as required by the *Open Meetings Act, Chapter 551, Gov't. Code.*

SECTION V
Provisions Cumulative

All other terms and provisions of the Levelland Code of Ordinances not in conflict herewith and not hereby amended shall remain in full force and effect. The passage of this Ordinance shall repeal any wording of any existing ordinance that conflicts with the wording of this Ordinance.

INTRODUCED, PASSED, and APPROVED on its first reading this 1st day of December, 2025.

PASSED, APPROVED, and ADOPTED on its second and final reading this 15th day of December, 2025.

CITY OF LEVELLAND, TEXAS

By: 
Breann Buxkemper, Mayor

ATTEST:



Andréa Corley, TRMC
City Secretary